

**University of Missouri Bid Event: Addendum 1**

**Event ID:** UOFMO- 20 2239 WJ K

**Event Dated:** May 11, 2020

**Event Name:** Parking Lot Striping

---

The questions listed below were received from the bidding community. The corresponding answers were provided by the requesting department. The specifications listed in the table below are modified as follow and except as set forth herein, otherwise remain unchanged and in full force and effect:

**Addendum 1, dated May 21, 2020**

| QUESTION   | ANSWER  |
|--|---|
| Most ADA stencils are in blue fields. Several are not. Some are blue symbols only, others white or black. Should the ones without the blue field be converted to blue field? | Preference to all be the blue field.  |
| Stalls with ADA &/or Disability signage but without any painted symbol. Add symbol?  | There are some spaces on campus that are designated as disability but not ADA accessible, those would not have painted symbols – All else should, |
| Admin Bldg (west side) and Law Bldg both appear to have new curb. Should it be painted?  | Not at this time.   |
| Red Fire Lanes: Bloch Hall, Law, Bloch exec Hall & Admin locations not listed as having Fire Lane. All currently have Fire Lane. Restripe?                                   | If it is painted as a red fire lane now, it should be repainted as red.   |
| Bixby, should drive lane curb be included?   | Not at this time.   |

|   |  |
|---|--|
| Parallel stalls on 48th (Area 37) are not painted. Add striping?  | Not at this time                                   |
| Should crosswalks in drive lanes/roadways be excluded?  | Yes  |
| Cherry St Garage has both yellow and white arrows. Restripe both? Convert all to yellow? Skip the white ones? | All to yellow                                      |
| Permit Area 28B, is this labeled 28W on the map?  | Yes - Sorry  |
| Should we not paint any existing Preformed Thermo markings?   | Depends on what shape it is in.                    |
| Does anything/everthing receive 2 coats of paint? Not at this time.   | Expectation is that one coat should be sufficient. |
| Glass beads are spec'd. What gets glass beads? Everything? Just markings in the drive lanes?                  | At this time just drive lanes.                     |

University of Missouri Strategic Sourcing Specialist

Wade A. Jadwin