

ADDENDUM NUMBER 1

**DATED JULY 1, 2021
TO
SPECIFICATIONS TO REQUEST FOR BIDS #21144
FOR
UPS Equipment and Maintenance**



MISSOURI

The above entitled specifications are hereby modified as follows and except as set forth herein otherwise remain unchanged and in full force and effect.

Questions and Answers

1. **Question:** Do you have the make, model, kVA, and serial number information?

Answer:

Power Converter Modules (3)

Make: Liebert
Model: U39MM450A0AB292
KVA: 450 (Output)
Serial Number: D06M5B0001

Make: Liebert
Model: U39MM450A0AB293
KVA: 450 (Output)
Serial Number: D06M5B0002

Make: Liebert
Model: U39MM450A0AB053
KVA: 450 (Output)
Serial Number: D11D5B00001

Uninterruptible Power System

Make: Liebert
Model: U39CC12M4AT292
KVA: 998 (Output)
Serial Number: D06L630024



2. **Question:** There are battery replacement and maintenance requests. How could you separate the prices for the maintenance and battery replacements on the provided form?

Answer: We do seek the replacement and maintenance as described in the bid. You can enter the pricing specifics on the Request for Proposal Form, under the chart is needed

3. **Question:** Would you accept equal/substitution for the batteries?

Answer: We cannot do substitution for the batteries given our expectations on the mandatory requirements

4. **Question:** What is the quantity of the batteries each UPS unit requires?

Answer: Each UPS module has a minimum two strings of batteries (40 batteries per string). UPS module #1 is equipped with three strings of batteries (120 batteries total), UPS #2 and #3 are each equipped with two strings.

The replacement process for the batteries is they are replaced one string at a time in order to maintain service for the data center.

THE CURATORS OF THE UNIVERSITY OF MISSOURI

Melissa Wampler

By: Melissa Wampler, MS, PMI-PBA
IT- Strategic Sourcing Specialist
University of Missouri System Procurement

MISSOURI