



NOTES:

1. PIPE VENT SHALL BE MUSHROOM TYPE WITH GALVANIZED CAST IRON BODY, 30 MESH STAINLESS STEEL SCREEN, POSITIVE STOP AND 4" NPT CONNECTION, OIL EQUIPMENT MANUFACTURING CORP. FIG NO. 4028 OR APPROVED EQUAL.



REV	DATE	Construction Standard Typical Chase Vent		DRAWING NOT TO SCALE DATE: 1/3/12
0	1/3/12			
1	12/26/13	Energy Management Campus Facilities UNIVERSITY OF MISSOURI-COLUMBIA		
2	6/5/14			
3	10/29/15			
DRAWN BY: TG				
CHECKED BY: TG				