



NON-PLANT CHILLED WATER FLOW DIAGRAM

SCALE: NONE

GENERAL NOTE

ALL SERVICE VALVES AND CONTROL VALVES TO BE LINE SIZE UNLESS SHOWN WITH REDUCED AND DIMENSION FITTINGS OR NOTED OTHERWISE.

NON-PLANT BUILDING CHILLED WATER POINTS LIST

TYPE	NAME	POINT DESCRIPTION	SEMANTIC TAGS	UNITS	FREQ		SERVICE		FIELD DEVICE DESCRIPTION	NOTES
					ARCHIVE	FREQ	ARCHIVE	FREQ		
GLOBAL POINTS (TO BE MAPPED TO UNIT CONTROLLER)										
AV	QA-T	OUTSIDE AIR TEMPERATURE REFERENCE	OUTSIDE AIR_TEMP_SENSOR_REF	'F 1	-	-	-	-	SAS POINT MAPPED TO CONTROLLER	
AV	QA-H	OUTSIDE AIR RELATIVE HUMIDITY REFERENCE	OUTSIDE AIR_HUMIDITY_SENSOR_REF	% RH 1	-	-	-	-	SAS POINT MAPPED TO CONTROLLER	
AV	QA-DWP	OUTSIDE AIR DRYPOINT REFERENCE	OUTSIDE AIR_DRYPOINT_SENSOR_REF	'F 1	-	-	-	-	SAS POINT MAPPED TO CONTROLLER	
CHILLED WATER SYSTEM POINTS										
AI	TS-CHW	CHW RETURN TO CAMPUS LOOP-HEADER TEMPERATURE	CHILLED_WATER_LEAVING_TEMP_SENSOR	'F 1	1 MIN	30 MIN	15 MIN	1 WEEK	INSERTION ELEMENT FLUID TEMPERATURE SENSOR	
AI	TS-CHWS	CHW SUPPLY LOOP-HEADER TEMPERATURE	CHILLED_WATER_ENTERING_TEMP_SENSOR	'F 1	1 MIN	30 MIN	15 MIN	1 WEEK	INSERTION ELEMENT FLUID TEMPERATURE SENSOR	
AI	TS-CHWR	CHW RETURN FROM BUILDING LOOP-TEMPERATURE	CHILLED_WATER_LEAVING_TEMP_SENSOR	'F 1	1 MIN	30 MIN	15 MIN	1 WEEK	INSERTION ELEMENT FLUID TEMPERATURE SENSOR	
AI	TS-CHWS	CHW SUPPLY TO BUILDING LOOP-TEMPERATURE	CHILLED_WATER_ENTERING_TEMP_SENSOR	'F 1	1 MIN	30 MIN	15 MIN	1 WEEK	INSERTION ELEMENT FLUID TEMPERATURE SENSOR	
AO	CV-CP	CHILLED WATER LOOP DIFFERENTIAL PRESSURE	CHILLED_WATER_PUMP_PRESSURE	% 0	1 MIN	30 MIN	15 MIN	1 WEEK	HYDROKING DIFFERENTIAL PRESSURE TRANSDUCER	PIPED FROM SUPPLY TO RETURN TO GET SYSTEM
AO	WFD-CP#1	CHILLED WATER PUMP 1 SPEED COMMAND	CHILLED_WATER_PUMP_SPEED_CMD	% 0	1 MIN	30 MIN	15 MIN	1 WEEK	HWIWIRED POINT TO CONTROLLED DEVICE	4-10 MA=10 VDC, COORD. WITH WFD
AO	WFD-CP#2	CHILLED WATER PUMP 2 SPEED COMMAND	CHILLED_WATER_PUMP_SPEED_CMD	% 0	1 MIN	30 MIN	15 MIN	1 WEEK	HWIWIRED POINT TO CONTROLLED DEVICE	4-10 MA=10 VDC, COORD. WITH WFD
AV	CV-CHW	CHILLED WATER BY PASSES VALVE COMMAND	CHILLED_WATER_PUMP_VALVE_CMD	% 0	1 MIN	30 MIN	15 MIN	1 WEEK	HWIWIRED POINT TO CONTROLLED DEVICE	
AV	HZ-CP#1	CHILLED WATER PUMP 1 SPEED FEEDBACK	CHILLED_WATER_PUMP_FREQ_SENSOR	HZ 0	1 MIN	30 MIN	15 MIN	1 WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	
AV	HZ-CP#2	CHILLED WATER PUMP 2 SPEED FEEDBACK	CHILLED_WATER_PUMP_FREQ_SENSOR	HZ 0	1 MIN	30 MIN	15 MIN	1 WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	
AV	FLD-CHW	CHILLED WATER LOOP FLOW	CHILLED_WATER_FLOW_SENSOR	SPM 0	1 MIN	30 MIN	15 MIN	1 WEEK	STRIP-ON-LO TRACKING FLUID FLOW MEASUREMENT	INTEGRATE VIA BACNET
AV	MEG-TOT	FLOW METER NEGATIVE TOTALIZER	N/A	Gal, 0	1 MIN	30 MIN	15 MIN	1 WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	INTEGRATE VIA BACNET
AV	POS-TOT	FLOW METER POSITIVE TOTALIZER	N/A	Gal, 0	1 MIN	30 MIN	15 MIN	1 WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	INTEGRATE VIA BACNET
AV	SG-STR	FLOW METER SIGNAL STRENGTH	N/A	A, 0	1 MIN	30 MIN	15 MIN	1 WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	INTEGRATE VIA BACNET
AV	MEG-TOT	FLOW METER NEGATIVE TOTALIZER	N/A	OFF ON	1 MIN	30 MIN	15 MIN	1 WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	INTEGRATE VIA BACNET
AV	AL-CP#1	CHILLED WATER PUMP 1 VFD ALARM	N/A	NORM/ALARM	1 MIN	30 MIN	15 MIN	1 WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	INTEGRATE VIA BACNET
AV	AL-CP#2	CHILLED WATER PUMP 2 VFD ALARM	N/A	NORM/ALARM	1 MIN	30 MIN	15 MIN	1 WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	INTEGRATE VIA BACNET
AV	AL-CP#3	CHILLED WATER PUMP 1 ALARM	N/A	NORM/ALARM	1 MIN	30 MIN	15 MIN	1 WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	INTEGRATE VIA BACNET
BI	ST-CP#1	CHILLED WATER PUMP 1 STATUS	CHILLED_WATER_PUMP_RUN_SENSOR	OFF ON	1 MIN	30 MIN	15 MIN	1 WEEK	FIXED TRIP CURRENT SWITCH	
BI	ST-CP#2	CHILLED WATER PUMP 2 STATUS	CHILLED_WATER_PUMP_RUN_SENSOR	OFF ON	1 MIN	30 MIN	15 MIN	1 WEEK	FIXED TRIP CURRENT SWITCH	
BO	SS-CP#1	CHILLED WATER PUMP 1 START/STOP	CHILLED_WATER_PUMP_RUN_CMD	OFF ON	1 MIN	30 MIN	15 MIN	1 WEEK	DRY CONTACT / RELAY	
BO	SS-CP#2	CHILLED WATER PUMP 2 START/STOP	CHILLED_WATER_PUMP_RUN_CMD	OFF ON	1 MIN	30 MIN	15 MIN	1 WEEK	DRY CONTACT / RELAY	

GENERAL NOTES

- FOR ANALOG POINTS, UNITS COLUMN HAS TWO COMPONENTS: FIRST VALUE INDICATES ENGINEERING UNITS FOR POINT, SECOND VALUE IS HARBERT'S PLACE TO DISPLAY.
- FOR BINARY POINTS, UNITS COLUMN LISTS "OFF" AND "ON" STATE LABELS FOR POINT.

SEQUENCE OF OPERATION (SOO) - CHILLED WATER BYPASS FLOW CONTROL AT NON-PLANT BUILDING ON CAMPUS CHW LOOP

- A. Overview: This system consists of a chilled water (CHW) bypass flow control valve and (4) Platinum RTD temperature sensors. CHW is pumped with one or more building pumps to the building (tertiary) CHW loads. An appropriately sized bypass leg decouples the loop (secondary) and building (tertiary) CHW systems. The bypass flow control valve controls the amount of CHW that is imported from the loop (secondary) to the building (tertiary) system such that the loop (secondary) side CHW delta-T is maximized.
- B. PID Loop Definitions: The following PID loop shall be provided at the system device controller:

PID Loop #1 (Tertiary Chilled Water Bypass Flow Control)

PID Loop Description	Point Name	Units	Point Description
1. PID Input Point Name:	FLOWINP1	%	Bypass Recirculation Flowrate Error as Percentage of Secondary Flowrate
2. PID Set-Point:	0	%	Percent Error
3. PID Output Point Name:	BYPVLCMD1	%	Output Range from 0 to 100
4. PID Loop Action:	Direct Acting		
5. PID Loop Reset:	See Section C for PID Enable and Output Bias		

- C. Software & Hardware Point Definitions: **LCT Programming** is required at a higher-level controller and shall be remotely accessible for commissioning purposes.

Point Number	Point Name	Point Description and Formula
1.	SYSX OAWBMIN1	Minimum Outdoor Air Wet Bulb Temperature for Span Block, deg F (User Adjustable)
		OAWBMIN1 = 30
2.	SYSX OAWBMAX1	Maximum Outdoor Air Wet Bulb Temperature for Span Block, deg F (User Adjustable)
		OAWBMAX1 = 60
3.	SYSX T2HIGH	Maximum Acceptable Tertiary CHW Supply Temperature, deg F (User Adjustable)
		T2HIGH = CAMPUS_CHWSP + OFFSET1
4.	SYSX OFFSET1	Winter Offset to Maximum Acceptable Tertiary CHW Supply Temperature, deg F
		OFFSET1 = Output from SPAN Block [OAWBAVG, OAWBMIN1, 2, OAWBMAX1, 1]
5.	SYSX CHIGH1	Highest Re-circulated CHW Tertiary Flow as % of Design Tertiary Flow for Span Block (User Adjustable)
		CHIGH1 = 2 (Value is dependent on building properties)
6.	SYSX CLOW1	Lowest Re-circulated Tertiary CHW Flow as % of Design Tertiary Flow for Span Block (User Adjustable)
		CLOW1 = 1 (Value is dependent on building properties)
7.	SYSX C1	Desired Re-circulated Tertiary CHW Flow % calculated using span block
		C1 = Output from SPAN Block [OAWBAVG, OAWBMIN1, CHIGH1, OAWBMAX1, CLOW1]

8.	SYSX OAT	Outdoor Air Temperature, deg F
		OAT = Mapped from Campus Weather Station, deg F
9.	SYSX OARH	Outdoor Air Relative Humidity, %
		OARH = Mapped from Campus Weather Station
10.	SYSX OAWB	Outdoor Air Wet Bulb Temperature, deg F
		Calculated Outdoor Air Wet Bulb based on OAT and OARH
11.	SYSX OAWBAVG	Time Averaged Outdoor Air Wet Bulb Temperature, deg F
		Calculate average value of OAWB over 108 consecutive scans
12.	SYSX BYPVMIN1	Minimum PID Output Value (User Adjustable)
		BYPVMIN1 = 10
13.	SYSX BYPVMAX1	Maximum PID Output Value (User Adjustable)
		BYPVMAX1 = 100
14.	SYSX PB1	Proportional Band Term – Mapped to Device Controller with Bypass Flow Control PID Loop (User Adjustable)
		PB1 = 800
15.	SYSX IT1	Integral Term – Mapped to Device Controller with Bypass Flow Control PID Loop (User Adjustable)
		IT1 = 48 sec
16.	SYSX STARTVAL1	PID Output Value when PID loop goes from Disabled to Enabled State (User Adjustable)
		STARTVAL1 = 30
17.	SYSX STOPVAL1	PID Output Value when PID loop goes from Enabled to Disabled State (User Adjustable)
		STOPVAL1 = BYPVMIN1
18.	SYSX PID1ENABLE	PID Loop Enable and Disable Criteria
		If all tertiary CHW pumps are disabled, as confirmed by run status, for 60 seconds continuously, then PID1ENABLE = FALSE else PID1ENABLE = TRUE
19.	SYSX T2MINUST1	Common tertiary CHW supply temperature minus secondary CHW supply temperature
		$T2MINUST1 = \text{MAX} \{0, (T2CHWS - \text{MAX} (T1CHWS, T2HIGH))\}$
20.	SYSX T4MINUST2	Tertiary CHW return temperature minus tertiary CHW supply temperature
		$T4MINUST2 = \text{MAX} \{2, (T4CHWR - T2CHWS)\}$
21.	SYSX T5MINUST4	Secondary CHW return temperature minus tertiary CHW return temperature
		IF T2MINUST1 > 0.25 THEN T5MINUST4 = 0 ELSE IF T2MINUST1 < 0.05 THEN T5MINUST4 = MIN {0, (T5CHWR – T4CHWR)} ENDIF
22.	SYSX FLOWINP1	Tertiary re-circulated bypass flow error percentage
		$\text{FLOWINP1} = \text{MIN} [100, \text{MAX} (5, \text{CHWBYPVLV}) * \{(T2MINUST1 / T4MINUST2) + (T5MINUST4 / T4MINUST2) - (C1 / 100)\}]$
23.	SYSX CHWBYPVLV	Tertiary CHW Bypass Flow Control Valve % Open Command. Command Mapped to Device Controller
		$\text{CHWBYPVLV} = \text{BYPVLVCMD1} * \text{PID1ENABLE}$