



NON-PLANT HEATING WATER FLOW DIAGRAM

GENERAL NOTE
ALL SERVICE VALVES AND CONTROL VALVES TO BE LINE SIZE UNLESS SHOWN WITH REDUCED AND/OR ENLARGED FITTINGS OR NOTED OTHERWISE.

NON-PLANT BUILDING - HEATING HOT WATER POINTS LIST

TYPE	NAME	DESCRIPTION	POINT DESCRIPTION	SEMANTIC TAGS	UNITS	FREQ		ARCHIVE		FIELD DEVICE DESCRIPTION		NOTES		
						FREQ	ARCHIVE	FREQ	ARCHIVE	INSTRUMENT TYPE				
GLOBAL POINTS (TO BE MAPPED TO OTHER CONTROLLERS)														
AI	GA_1	OUTSIDE AIR TEMPERATURE	OUTSIDE AIR TEMP	TEMP_SENSOR	°F	1	MIN	30	MIN	1	WEEK	OUTDOOR AIR TEMPERATURE SENSOR		
AI	GA_2	OUTSIDE AIR RELATIVE HUMIDITY	OUTSIDE AIR RELATV HUMIDITY	REL_HUMIDITY_SENSOR	% RH	-	-	-	-	-	-	GENERAL PURPOSE OUTSIDE RELATV HUMIDITY SENSOR		
AV	GA_DAMP	OUTSIDE AIR DDPV POINT REFERENCE	OUTSIDE AIR DDPV POINT REFERENCE	SOFTWARE_VIRTUAL_POINT	-	-	-	-	-	-	-	SOFTWARE VIRTUAL POINT		
AV	GA_WB	OUTSIDE AIR WB DDPV POINT REFERENCE	OUTSIDE AIR WB DDPV POINT REFERENCE	SOFTWARE_VIRTUAL_POINT	-	-	-	-	-	-	-	SOFTWARE VIRTUAL POINT		
HOT WATER SYSTEM POINTS														
AI	THSM1	HW RETURN TO CAMPUS LOOP HEADER TEMPERATURE	HEATING WATER LEAVING TEMP SENSOR	TEMP_SENSOR	°F	1	MIN	30	MIN	15	MIN	1	WEEK	INSERTION ELEMENT FLUID TEMPERATURE SENSOR
AI	THSM5	HW SUPPLY LOOP HEADER TEMPERATURE	HEATING WATER ENTERING TEMP SENSOR	TEMP_SENSOR	°F	1	MIN	30	MIN	15	MIN	1	WEEK	INSERTION ELEMENT FLUID TEMPERATURE SENSOR
AI	THSM6	HW RETURN FROM BUILDING LOOP TEMPERATURE	HEATING WATER LEAVING TEMP SENSOR	TEMP_SENSOR	°F	1	MIN	30	MIN	15	MIN	1	WEEK	INSERTION ELEMENT FLUID TEMPERATURE SENSOR
AI	THSM5	HW SUPPLY TO BUILDING LOOP TEMPERATURE	HEATING WATER ENTERING TEMP SENSOR	TEMP_SENSOR	°F	1	MIN	30	MIN	15	MIN	1	WEEK	INSERTION ELEMENT FLUID TEMPERATURE SENSOR
AI	WEL_DP	HEATING WATER LOOP DIFFERENTIAL PRESSURE	CHILLED WATER PUMP PRESSURE	PRESS_SENSOR	PSI	1	MIN	30	MIN	15	MIN	1	WEEK	DIFFERENTIAL PRESSURE TRANSDUCER
AO	WEL_HWP1	HEATING WATER PUMP 1 SPEED COMMAND	HEATING WATER PUMP SPEED CMD	CONTROL_VALVE	%	0	MIN	30	MIN	15	MIN	1	WEEK	HW PUMP POINT TO CONTROLLED DEVICE
AO	WEL_HWP2	HEATING WATER PUMP 2 SPEED COMMAND	HEATING WATER PUMP SPEED CMD	CONTROL_VALVE	%	0	MIN	30	MIN	15	MIN	1	WEEK	HW PUMP POINT TO CONTROLLED DEVICE
AO	CV_WV	HEATING WATER BY PASS VALVE COMMAND	HEATING WATER VALVE CMD	CONTROL_VALVE	%	0	MIN	30	MIN	15	MIN	1	WEEK	HW PUMP POINT TO CONTROLLED DEVICE
AV	HL_HWP1	HEATING WATER PUMP 1 SPEED FEEDBACK	HEATING WATER PUMP FREQ SENSOR	FREQ_SENSOR	Hz	0	MIN	30	MIN	15	MIN	1	WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE
AV	HL_HWP2	HEATING WATER PUMP 2 SPEED FEEDBACK	HEATING WATER PUMP FREQ SENSOR	FREQ_SENSOR	Hz	0	MIN	30	MIN	15	MIN	1	WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE
AV	FLO_WV	HEATING WATER LOOP FLOW	HEATING WATER FLOW SENSOR	FLOW_SENSOR	GPM	0	MIN	30	MIN	15	MIN	1	WEEK	STRAP ON ULTRASONIC FLUID FLOW MEASUREMENT
AV	MSL_TOT	FLOW METER NEGATIVE TOTALIZER	N/A	GAL	0	MIN	30	MIN	15	MIN	1	WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	
AV	POS_TOT	FLOW METER POSITIVE TOTALIZER	N/A	GAL	0	MIN	30	MIN	15	MIN	1	WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	
AV	MSL_STR	FLOW METER DOWN COUNTDOWN	N/A	GAL	0	MIN	30	MIN	15	MIN	1	WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	
AV	RES_TOT	FLOW METER TOTALIZER RESET	N/A	OFF / ON	N/A	0	MIN	30	MIN	15	MIN	1	WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE
AV	AL_HWP1	HEATING WATER PUMP 1 FLD ALARM	N/A	NORM / ALARM	1	MIN	30	MIN	15	MIN	1	WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	
AV	AL_HWP2	HEATING WATER PUMP 2 FLD ALARM	N/A	NORM / ALARM	1	MIN	30	MIN	15	MIN	1	WEEK	NETWORK INTERFACE TO CONTROLLED DEVICE	
BI	ST_HWP1	HEATING WATER PUMP 1 STATUS	HEATING WATER PUMP RUN SENSOR	OFF / ON	1	MIN	30	MIN	15	MIN	1	WEEK	FREQ TRIP CURRENT SWITCH	
BI	ST_HWP2	HEATING WATER PUMP 2 STATUS	HEATING WATER PUMP RUN SENSOR	OFF / ON	1	MIN	30	MIN	15	MIN	1	WEEK	FREQ TRIP CURRENT SWITCH	
BO	SD_HWP1	HEATING WATER PUMP 1 2ENBLE	HEATING WATER PUMP RUN CMD	OFF / ON	1	MIN	30	MIN	15	MIN	1	WEEK	DRY CONTACT / RELAY	
BO	SD_HWP2	HEATING WATER PUMP 2 2ENBLE	HEATING WATER PUMP RUN CMD	OFF / ON	1	MIN	30	MIN	15	MIN	1	WEEK	DRY CONTACT / RELAY	
GENERAL NOTES														
BI	BI	BINARY INPUT												
BO	BO	BINARY OUTPUT												
AV	AV	ANALOG INPUT												
AO	AO	ANALOG OUTPUT												
AV	AV	ANALOG VIRTUAL POINT												
HW	HW	HEATING WATER POINT												
ODS	ODS	CHANGE OF STATE												

SEQUENCE OF OPERATION (SOO) - HEATING WATER BYPASS FLOW CONTROL AT NON-PLANT BUILDING ON CAMPUS HEATING WATER LOOP

- A. Overview: This system consists of a heating water (HW) bypass flow control valve and (4) Platinum RTD temperature sensors. HW is pumped with one or more building pumps to the building (tertiary) HW loads. An appropriately sized bypass leg decouples the secondary and tertiary HW systems. The bypass flow control valve controls the amount of HW that is imported from the loop (secondary) to the building (tertiary) such that the loop (secondary) side HW delta-T is maximized.
- B. PID Loop Definitions: The following PID loop shall be provided at the system device controller:

PID Loop #2 (Tertiary Heating Water Bypass Flow Control)

PID Loop Description	Point Name	Units	Point Description
1. PID Input Point Name:	FLOWINP2	%	Bypass Recirculation Flowrate Error as Percentage of Loop Flowrate
2. PID Set-Point:	0	%	Percent Error
3. PID Output Point Name:	BYPVLCMD2	%	Output Range from 0 to 100
4. PID Loop Action:	Direct Acting		
5. PID Loop Reset:	See Section C for PID Enable and Output Bias		

- C. Software & Hardware Point Definitions: **LCT Programming** is required at a higher-level controller and shall be remotely accessible for commissioning purposes.

Point Number	Point Name	Point Description and Formula
1.	SYSX T1MINUST2	Common secondary HW supply temperature minus tertiary HW supply temperature $T1MINUST2 = \text{MAX} \{0, (\text{MIN} (T1HWS, T2LOW) - T2HWS)\}$
2.	SYSX T2MINUST4	Tertiary HW supply temperature minus tertiary HW return temperature $T2MINUST4 = \text{MAX} \{1.0, (T2HWS - T4HWR)\}$
3.	SYSX T4MINUST5	Tertiary HW return temperature minus secondary HW return temperature IF T1MINUST2 > 0.25 THEN T4MINUST5 = 0 ELSE IF T1MINUST2 < 0.05 THEN T4MINUST5 = MIN {0, (T4HWR - T5HWR)} ENDIF
4.	SYSX FLOWINP2	Building re-circulated bypass flow error percentage $\text{FLOWINP2} = \text{MIN} [100, \text{MAX} (5, \text{HWBYPVLV}) * \{(T1MINUST2 / T2MINUST4) + (T4MINUST5 / T2MINUST4) - C2 / 100\}]$
5.	SYSX OATMIN2	Minimum Outdoor Air Dry-Bulb Temperature for Span Block, deg F (User Adjustable) OATMIN2 = 30

6.	SYSX OATMAX2	Maximum Outdoor Air Dry-Bulb Temperature for Span Block, deg F (User Adjustable)
		OATMAX2 = 60
7.	SYSX T2LOW	Minimum Acceptable Tertiary HW Supply Temperature, deg F (User Adjustable)
		T2LOW = CAMPUS_HWSP – OFFSET2
8.	SYSX CHIGH2	Highest Re-circulated HW Building Flow as % of Design Building Flow for Span Block (User Adjustable)
		CHIGH2 = 2
9.	SYSX CLOW2	Lowest Re-circulated Building HW Flow as % of Design Building Flow for Span Block
		CLOW2 = 1
10.	SYSX C2	Desired Re-circulated Building HW Flow % calculated using span block
		C2 = Output from SPAN Block [OATAVG, OATMIN2, CLOW2, OATMAX2, CHIGH2]
11.	SYSX OAT	Outdoor Air Temperature, deg F
		OAT = Mapped from Weather Station
12.	SYSX OARH	Outdoor Air Relative Humidity, %
		OARH = Mapped from Weather Station
13.	SYSX OAWB	Outdoor Air Wet Bulb Temperature, deg F
		Calculated Outdoor Air Wet Bulb based on OAT and OARH
14.	SYSX OATAVG	Time Averaged Outdoor Air Temperature, deg F
		Calculate average value of OAT over 108 consecutive scans
15.	SYSX OFFSET2	Offset to Minimum Acceptable Tertiary HW Supply Temperature, deg F
		OFFSET2 = Output from SPAN Block [OATAVG, OATMIN2, 1, OATMAX2, 2]
16.	SYSX BYPVMIN2	Minimum PID Output Value (User Adjustable)
		BYPVMIN2 = 10
17.	SYSX BYPVMAX2	Maximum PID Output Value (User Adjustable)
		BYPVMAX2 = 100
18.	SYSX PB2	Proportional Band Term – Mapped to Device Controller with PID Loop #2
		PB2 = 800
19.	SYSX IT2	Integral Term – Mapped to Device Controller with the PID Loop #2
		IT2 = 48 sec
20.	SYSX STARTVAL2	PID Output when Enabled
		STARTVAL2 = 30
21.	SYSX STOPVAL2	PID #2 Output when Disabled
		STOPVAL2 = BYPVMIN2
22.	SYSX PID2ENABLE	PID #2 Enable and Disable Criteria
		If all tertiary HW pumps are disabled, as confirmed by run status, for 60 seconds continuously, then PID2ENABLE = FALSE else PID2ENABLE = TRUE
23.	SYSX HWBYPVLV	Tertiary HW Bypass Flow Control Valve % Open Command. Command Mapped to Device Controller
		HWBYPVLV = BYPVLVCMD2 * PID2ENABLE