



FCU CW AND HW PIPING DETAIL

SCALE: NONE

- 1 PROVIDE PICV WITH A FLOW RATING THAT MATCHES THE COIL SUBMITTAL FLOWRATE, OR THE NEXT AVAILABLE FLOWRATE GREATER THAN THE COIL SUBMITTAL FLOWRATE.
- 2 PROVIDE LINE SIZED DRAINS WITH THREADED DRAIN VALVE WITH CAP/PLUG.
- 3 PROVIDE MANUAL THREADED AIR VENTS WITH CAP/PLUG.
- 4 RUNNOUT PIPING TO VAV COIL SHALL BE AT LEAST 3/4".