



MC CABLE ALLOWED FOR BRANCH CIRCUITS IN ACCESSIBLE AREAS ONLY:

- ABOVE DROPPED ACOUSTICAL TILE GRID CEILINGS AND IN STUD/WALLS ARE CONSIDERED ACCESSIBLE.
- HARD CEILINGS AND MASONRY WALLS ARE INACCESSIBLE AND MC CABLE IS NOT ALLOWED.
- IS ALLOWED IN ACCESSIBLE ATTICS ABOVE HARD CEILINGS.
- NOT ALLOWED FOR HOME RUN CIRCUITS.
- IS ALLOWED BETWEEN ROOMS IN ACCESSIBLE AREAS ONLY.
- TOTAL LENGTH OF MC CABLE SHALL NOT EXCEED 50'-0" BETWEEN CONNECTIONS.
- CANNOT CROSS CORRIDORS.
- NOT ALLOWED FOR FEEDER CIRCUITS TO BRANCH PANELS.
- NOT ALLOWED FOR EMERGENCY CIRCUITS,

TYPE
based
on
size

LEGEND	
—	CONDUIT
- - -	MC CABLE
J	JUNCTION BOX

ALLOWABLE RACEWAY INSTALLATIONS

N.T.S.

NOTE: This does not apply to projects for MU Health Care.