



NOTE: ALL EXTERIOR METAL PIPE, VALVES, FITTINGS, CLAMPS, ETC. SHALL BE WRAPPED WITH POLYETHYLENE COVER.

REV	DATE
1	10/27/04
2	8/10/06
3	6/05/14
4	11/05/15
DRAWN BY: BB	
CHECKED BY: TG	

## Construction Standard Water Distribution Wall Penetration

Energy Management  
 Campus Facilities  
 UNIVERSITY OF MISSOURI



DRAWING  
 NOT TO SCALE  
 DATE: 12/22/02