

EXPANSION JOINT SCHEDULE

JOINT MK.	LOCATION	SIZE	TYPE	ENDS	SERVICE	PRESSURE PSIG	TEMP. °F	RATED TRAVEL	MAX. OAL
EJ-S1	MANHOLE NO. 154	10"	EXTERNALLY PRESSURIZED BELLOWS	WELD	STEAM	70	450	6"	34"
EJ-S2	MANHOLE NO. 154	8"	EXTERNALLY PRESSURIZED BELLOWS	WELD	STEAM	70	450	3"	21"
EJ-C1	MANHOLE NO. 154	6"	EXTERNALLY PRESSURIZED BELLOWS	WELD	CONDENSATE	100	200	3"	33"
EJ-C2	MANHOLE NO. 154	3"	EXTERNALLY PRESSURIZED BELLOWS	WELD	CONDENSATE	100	200	3"	24"

REV	DATE	Construction Standard Expansion Joint Schedule		
0	12/22/02			
1	1/13/03			
DRAWN BY: BB		Energy Management Campus Facilities UNIVERSITY OF MISSOURI-COLUMBIA		DRAWING NOT TO SCALE DATE: 12/22/02
CHECKED BY: TG				