


TYPICAL HPS AND PC  
PIPE SUPPORT DETAIL

NOTES:

1. PIPE SADDLES INSTALLED IN COLD CONDITION SHALL BE LOCATED OFF CENTER OPPOSITE THE DIRECTION OF EXPANSION SUCH THAT SADDLE BEARS ON SUPPORT IN BOTH HOT AND COLD POSITIONS.
2. 12" HPS TO BE SUPPORTED EVERY 24 FT. 6" PC TO BE SUPPORTED EVERY 12 FT

REV	DATE	Construction Standard Typical Pipe Support	
0	12/22/02		
1	1/13/03	Energy Management Campus Facilities UNIVERSITY OF MISSOURI-COLUMBIA	
2	08/06/09		
3	10/29/15		
DRAWN BY: BB			DRAWING NOT TO SCALE
CHECKED BY: TG			