



NOTES:

1. CONDUITS A,B&C TO TRANSFORMER.
2. CONDUITS 1-6 TO MANHOLE.
3. ALL SWITCH DOORS SHALL HAVE 8 FT. MINIMUM CLEARANCE.
4. ALL SWITCH OPERATOR HANDLES SHALL HAVE 3 FT. MINIMUM CLEARANCE.

REV	DATE
0	12/27/02
1	1/9/12
2	10/8/13
3	

DRAWN BY: CSS
REVISED BY: ZK

Construction Standard PMU Pad Detail

337700



UNIVERSITY OF MISSOURI-COLUMBIA
Campus Facilities
Energy Management

DRAWING
NOT TO SCALE
DATE: 9/22/1997